

ISO NEW ENGLAND PLANNING PROCEDURE NO. 3

**RELIABILITY STANDARDS FOR THE
NEW ENGLAND AREA BULK POWER SUPPLY SYSTEM**

EFFECTIVE DATE: March 5, 2010

REFERENCES:

- NPCC Reliability Reference Directory # 1 Design and Operation of the Bulk Power System, December 1, 2009 (Includes references to NERC ERO Reliability Standards)
- NPCC Regional Reliability Reference Directory # 2 Emergency Operations, October 21, 2008
- NPCC Reliability Reference Directory # 4 Bulk Power System Protection Criteria, December 1, 2009
- NPCC Document A-7, Glossary of Terms, Revised July 17, 2007
- NPCC Regional Reliability Reference Directory # 7 Special Protection Systems, December 27, 2007
- ISO New England Planning Procedure 5-5, Special Protection Systems Application Guidelines
- Damping Criterion Basis Document, Stability Task Force, Approved April 1, 2009.
- NERC NUC-001-2, Nuclear Plant Interface Coordination Reliability Standard, Adopted by NERC Board of Trustees: August 5, 2009
- NERC Glossary of Terms Used in Reliability Standards, Updated April 20, 2009

CONTENTS

1. INTRODUCTION	1
2. RESOURCE ADEQUACY	3
3. AREA TRANSMISSION REQUIREMENTS	4
3.1 STABILITY ASSESSMENT	5
3.2 STEADY STATE ASSESSMENT.....	6
3.3 FAULT CURRENT ASSESSMENT	6
4. TRANSMISSION TRANSFER CAPABILITY.....	6
4.1 NORMAL TRANSFERS	6
4.2 EMERGENCY TRANSFERS.....	7
5. EXTREME CONTINGENCY ASSESSMENT.....	7
6. EXTREME SYSTEM CONDITIONS ASSESSMENT.....	8
APPENDIX "A"	10
LIST OF DEFINITIONS	
APPENDIX "B"	13
GENERAL GUIDELINES FOR DEMONSTRATING COMPLIANCE WITH PLANNING PROCEDURE NO. 3, RELIABILITY STANDARDS FOR THE NEW ENGLAND AREA BULK POWER SUPPLY SYSTEM	
APPENDIX "C"	15
DAMPING CRITERION	

**RELIABILITY STANDARDS
FOR THE
NEW ENGLAND AREA BULK POWER SUPPLY SYSTEM**

1. INTRODUCTION

The ISO New England Transmission, Markets and Services Tariff (the “Tariff”) provides for the establishment of reliability standards for the bulk power supply system of the New England Area. The reliability standards set forth herein have been adopted as appropriate for the New England **bulk power supply system**¹. Further, they are consistent with those established by the Northeast Power Coordinating Council in the NPCC "Basic Criteria for Design and Operation of Interconnected Power Systems" and the NPCC "Bulk Power System Protection Criteria."

The purpose of these New England Reliability Standards is to assure the reliability and efficiency of the New England **bulk power supply system** through coordination of system planning, design and operation. These standards apply to all entities comprising or using the New England **bulk power supply system**. The host Governance Participant (the Governance Participant through which a non-Governance Participant connects to the **bulk power supply system**) shall use its best efforts to assure that, whenever it enters into arrangements with non-Governance Participants, such arrangements are consistent with these standards.

These Reliability Standards establish minimum design criteria for the New England **bulk power supply system**. It is recognized that more rigid design and operating criteria may be applied in some segments of the pool because of local considerations. Any constraints imposed by the more rigid criteria will be taken into account in all testing. It is also recognized that the Reliability Standards are not necessarily applicable to those **elements** that are not a part of the New England **bulk power supply system**.

Because of the long lead times required for the planning and construction of generation and transmission facilities versus the short lead times available for responding to changed operating conditions, it is necessary that criteria for planning and design vary in some respects from the System Rules used in actual operations. The intent is to have the system operate at the level of reliability that was contemplated at the time it was designed. For this reason, it is necessary that the design criteria simulate the effects of the equipment outages which may be expected to occur in actual operation. Nevertheless, it should be recognized that in actual operations, it may not always be possible to achieve the design level of reliability due to delays in construction of critical facilities, excessive forced outages, or loads exceeding the predicted levels.

¹ Terms in bold typeface are defined in Appendix A.

These Reliability Standards are intended to be used for planning and design of the New England **bulk power system**. Reliability criteria and procedures for operations are detailed elsewhere, with the primary reliability-related documents used in system dispatch and operations being:

1. ISO New England Operating Procedure No. 1 – Central Dispatch Operating Responsibility and Authority of ISO New England, the Local Control Centers and Market Participants
2. ISO New England Operating Procedure No. 3 – Transmission Outage Scheduling
3. ISO New England Operating Procedure No. 4 – Action During a Capacity Deficiency
4. ISO New England Operating Procedure No. 5 – Generation Maintenance and Outage Scheduling
5. ISO New England Operating Procedure No. 6 – System Restoration
6. ISO New England Operating Procedure No. 7 – Action in an Emergency
7. ISO New England Operating Procedure No. 8 – Operating Reserve and Regulation
8. ISO New England Operating Procedure No. 11 – Black Start Capability Testing Requirements
9. ISO New England Operating Procedure No. 12 – Voltage and Reactive Control
10. ISO New England Operating Procedure No. 13 – Standards for Voltage Reduction and Load Shedding Capability
11. ISO New England Operating Procedure No. 14 – Technical Requirements for Generators, Demand Resources and Asset Related Demands
12. ISO New England Operating Procedure No. 17 – Load Power Factor Correction
13. ISO New England Operating Procedure No. 18 – Metering and Telemetry Criteria
14. ISO New England Operating Procedure No. 19 – Transmission Operations

The New England **bulk power supply system** shall be designed for a level of reliability such that the loss of a major portion of the system, or unintentional separation of any portion of the system, will not result from reasonably foreseeable **contingencies**. Therefore, the system is required to be designed to meet representative **contingencies** as defined in these Reliability Standards. Analyses of simulations of these **contingencies** should include assessment of the potential for widespread cascading outages due to overloads, instability, voltage collapse, or the inability to meet the **Nuclear Plant Interface Requirements (NPIRs)**. The NPIRs for each nuclear plant generator subject to dispatch by ISO New England Inc. (ISO) are documented in its ISO Form NX-12 under ISO New England Operating Procedure No. 14 – Technical Requirements for Generators, Demand Resources and Asset Related

Demands. The loss of small portions of the system may be tolerated provided the reliability of the overall interconnected system is not jeopardized and the **NPIRs** are met.

The standards outlined hereinafter are not tailored to fit any one system or combination of systems but rather outline a set of guidelines for system design which will result in the achievement of the desired level of reliability and efficiency for the New England **bulk power supply system**.

2. RESOURCE ADEQUACY

Resources will be planned and installed in such a manner that, after due allowance for the factors enumerated below, the probability of disconnecting noninterruptible customers due to **resource** deficiency, on the average, will be no more than once in ten years. Compliance with this criteria shall be evaluated probabilistically, such that the loss of load expectation [LOLE] of disconnecting noninterruptible customers due to resource deficiencies shall be, on average, no more than 0.1 day per year.

- a. The possibility that load forecasts may be exceeded as a result of weather variations.
- b. Immature and mature **equivalent forced outage rates** appropriate for generating units of various sizes and types, recognizing partial and full outages.
- c. Due allowance for scheduled outages and deratings.
- d. Seasonal adjustment of **resource** capability.
- e. Proper maintenance requirements.
- f. Available operating procedures.
- g. The reliability benefits of interconnections with systems that are not Governance Participants.
- h. Such other factors as may from time-to-time be appropriate.

For planning purposes, the assumed **equivalent forced outage rate** of a generating unit connected to the transmission network by a radial transmission line will be increased to reflect the estimated transmission line forced outage rate if significant.

The potential power transfers from outside New England that are considered in determining the New

England capacity requirements must not exceed the **emergency** inter-Area transmission transfer capabilities, as determined in accordance with Section 4.2, using long term emergency (LTE) ratings.

3. AREA TRANSMISSION REQUIREMENTS

The New England **bulk power supply system** shall be designed with sufficient transmission capacity to integrate all **resources** and serve **area** loads and meet the applicable **NPIRs** under the conditions noted in Sections 3.1 and 3.2. These requirements will also apply after any critical generator, transmission circuit, transformer, phase angle regulating transformer, HVDC pole, series or shunt compensating device has already been lost, assuming that the **area resources** and power flows are adjusted between outages, using all appropriate reserve **resources** available in ten minutes and where applicable, any phase angle regulator control, and HVDC control.

With due allowance for generator maintenance and forced outages, design studies will assume power flow conditions with applicable transfers, load, and **resource** conditions that reasonably stress the system. Transfers of power to and from another **Area**, as well as within New England, shall be considered in the design of inter-Area and intra-Area transmission facilities.

Transmission transfer capabilities will be based on the load and **resource** conditions expected to exist for the period under study and shall be determined in accordance with Section 4.1 for normal transfers, and Section 4.2 for **emergency** transfers. All reclosing facilities will be assumed in service unless it is known that such facilities have been or will be rendered inoperative.

In applying these criteria, it is recognized that it may be necessary to restrict the output of a generating station(s) and/or HVDC terminal(s) following the loss of a system **element**. This may be necessary to maintain system stability or to maintain line loadings within appropriate thermal ratings in the event of a subsequent outage. But, the system design must be such that, with all transmission facilities in service, all **resources** required for reliable and efficient system operation can be dispatched without unacceptable restriction.

Special Protection Systems (SPSs) may be employed in the design of the interconnected power system. All SPSs proposed for use on the New England system must be reviewed by the Reliability Committee and NPCC and approved by the ISO. Some SPSs may also require acceptance by NPCC. The requirements for the design of SPSs are defined in the NPCC "Bulk Power System Protection Criteria" and the NPCC "Special Protection System Criteria". A set of guidelines for application of SPSs on the New England system are contained in the ISO New England Planning Procedure 5-6 "Special Protection Systems Application Guidelines".

3.1 STABILITY ASSESSMENT

The New England **bulk power supply system** shall remain stable and damped in accordance with the criterion specified in Appendix C during and following the most severe of the **contingencies** stated below **with due regard to reclosing**, and before making any manual system adjustments. For each of the **contingencies** below that involves a fault, stability and damping in accordance with the criterion specified in Appendix C shall be maintained when the simulation is based on **fault clearing** initiated by the “system A” **protection group**, and also shall be maintained when the simulation is based on **fault clearing** initiated by the “system B” **protection group** where such protection group is required or where there would otherwise be a significant adverse impact outside the local area.

- a. A permanent three-phase fault on any generator, transmission circuit, transformer, or bus section with **normal fault clearing**.
- b. Simultaneous permanent phase-to-ground faults on different phases of each of two adjacent transmission circuits on a multiple circuit transmission tower, with **normal fault clearing**. If multiple circuit towers are used only for station entrance and exit purposes, and if they do not exceed five towers at each station, then this condition and other similar situations can be excluded on the basis of acceptable risk, provided that the ISO specifically approves each request for exclusion. Similar approval must be granted by the NPCC Reliability Coordinating Committee.
- c. A permanent phase-to-ground fault on any transmission circuit, transformer or bus section with **delayed fault clearing**. This **delayed fault clearing** could be due to circuit breaker, relay system or signal channel malfunction.
- d. Loss of any **element** without a fault.
- e. A permanent phase-to-ground fault in a circuit breaker, with **normal fault clearing**. (**Normal fault clearing** time for this condition may not be high speed.)
- f. Simultaneous permanent loss of both poles of a **direct current bipolar** facility without an ac fault.
- g. The failure of any SPS which is not functionally redundant to operate properly when required following the **contingencies** listed in "a" through "f" above.
- h. The failure of a circuit breaker to operate when initiated by an SPS following: loss of any **element** without a fault; or a permanent phase to ground fault, with **normal fault clearing**, on any transmission circuit, transformer, or bus section.

3.2 STEADY STATE ASSESSMENT

- a. Adequate reactive power resources with reserves and appropriate controls shall be installed to maintain voltages within normal limits for pre-disturbance conditions, and within **applicable emergency limits** for the system conditions that exist following the **contingencies** specified in Section 3.1.
- b. Line and equipment loadings shall be within normal limits for pre-disturbance conditions and within **applicable emergency limits** for the system load and generation conditions that exist following the **contingencies** specified in Section 3.1.

3.3 FAULT CURRENT ASSESSMENT

The New **England bulk power supply system** shall be designed to ensure equipment capabilities are adequate for fault current levels with all transmission and generation facilities in service for all potential operating conditions.

4. TRANSMISSION TRANSFER CAPABILITY

The New England **bulk power supply system** shall be designed with adequate inter-Area and intra-Area transmission transfer capability to minimize system reserve requirements, facilitate transfers, provide **emergency** backup of supply **resources**, permit economic interchange of power, and to assure that the conditions specified in Sections 3.1 and 3.2 can be sustained without adversely affecting the New England system or other **Areas** and without violating the **NPIRs**. Anticipated transfers of power from one **area** to another, as well as within **areas**, should be considered in the design of inter-Area and intra-Area transmission facilities. Therefore, design studies will assume applicable transfers and the most severe load and **resource** conditions that can be reasonably expected.

Firm transmission transfer capabilities shall be determined for Normal and **Emergency** transfer conditions as defined in Sections 4.1 and 4.2. Normal transfer conditions are to be assumed except during an **Emergency** as defined by Item 7 in Appendix A. In determining the **emergency** transfer capabilities, a less conservative margin is justified.

4.1 NORMAL TRANSFERS

For normal transfer conditions the New England **bulk power supply system** shall remain stable and damped in accordance with the criterion specified in Appendix C in during and following the most severe of the conditions specified in Section 3.1 "a" through "h", **with due regard to reclosing**, and before making any manual system adjustments.

Voltages, line loadings and equipment loadings shall be within normal limits for pre-disturbance conditions and within **applicable emergency limits** for the system load and **resource** conditions that exist following any disturbance specified in Section 3.1.

4.2 EMERGENCY TRANSFERS

For **emergency** transfer conditions the New England **bulk power supply system** shall remain stable and damped in accordance with the criterion specified in Appendix C during and following the most severe of the **contingencies** stated in "a" and "b" below. **Emergency** transfer levels may require adjustment of **resources** and, where available, phase angle regulator controls and HVDC controls, before manually reclosing faulted **elements**.

- a. A permanent three-phase fault on any generator, transmission circuit, transformer, or bus section, with **normal fault clearing** and **with due regard to reclosing**.
- b. Loss of any **element** without a fault.

For **emergency** transfer conditions the pre-disturbance voltages, line, and equipment loadings shall be within **applicable emergency limits**. The post-disturbance voltages, line, and equipment loadings shall be within **applicable emergency limits** immediately following the **contingencies** above.

5. EXTREME CONTINGENCY ASSESSMENT

Extreme **contingency** assessment recognizes that the New England **bulk power system** can be subjected to events which exceed in severity the **contingencies** listed in Section 3.1. Planning studies will be conducted to determine the effect of the following extreme **contingencies** on New England **bulk power supply system** performance as a measure of system strength. Plans or operating procedures will be developed, where appropriate, to reduce the probability of occurrence of such **contingencies**, or to mitigate the consequences that are indicated as a result of the simulation of such **contingencies**.

- a. Loss of the entire capability of a generating station.
- b. Loss of all transmission circuits emanating from a generating station, switching station, dc terminal or substation.
- c. Loss of all transmission circuits on a common right-of-way.
- d. Permanent three-phase fault on any generator, transmission circuit, transformer or bus section,

with **delayed fault clearing** and **with due regard to reclosing**. This **delayed fault clearing** could be due to circuit breaker, relay system or signal channel malfunction.

- e. The sudden dropping of a large load or major load center.
- f. The effect of severe power swings arising from disturbances outside of New England.
- g. Failure of a **Special Protection System** to operate when required following the normal **contingencies** listed in Section 3.1 "a" through "f".
- h. The operation or partial operation of a **Special Protection System** for an event or condition for which it was not intended to operate.
- i. Common mode failure of the fuel delivery system that would result in the sudden loss of multiple plants (i.e. gas pipeline **contingencies**, including both gas transmission lines and gas mains).

6. EXTREME SYSTEM CONDITIONS ASSESSMENT

The New England **bulk power supply system** can be subjected to a wide range of other than normal system conditions that have low probability of occurrence. One of the objectives of extreme system conditions assessment is to determine through planning studies, the impact of these conditions on expected steady-state and dynamic system performance. This is done in order to obtain an indication of system robustness or to determine the extent of a widespread adverse system response.

Analytical studies will be conducted to determine the effect of design contingencies under the following extreme system conditions:

- a. Peak load conditions resulting from extreme weather conditions with applicable rating of electrical elements.
- b. Generating unit(s) fuel shortage, (e.g. gas supply unavailability).

After due assessment of extreme system conditions, measures may be utilized, where appropriate, to mitigate the consequences that are indicated as a result of testing for such extreme system conditions.

Document History²

Rev. 0 Rec.: RTPC - 6/8/99; App.: NEC - 7/9/99

Rev. 1 Rec.: RC - 12/7/04; App.: PC - 1/7/05

Rev. 2 Eff.: 2/1/05

Rev. 3 Rec.: RC – 8/29/06; Rec.:PC – 10/13/06; Eff. 10/13/06

Rev. 4 Rec.: RC – 5/19/09; Rec.:PC – 6/05/09; Eff. 6/11/09

Rev. 5 Modifications Only Address NERC Standard NUC-001-2

Rec.: RC – 2/26/10; Rec. PC – 3/05/10; Eff. 3/05/10

² This Document History documents action taken on the equivalent NEPOOL Procedure prior to the RTO Operations Date as well as revisions to the ISO New England Procedure subsequent to the RTO Operations Date.

APPENDIX “A”**LIST OF DEFINITIONS****1. APPLICABLE EMERGENCY LIMIT**

These **emergency** limits depend on the duration of the occurrence, and are subject to New England standards.

Emergency limits are those which can be utilized for the time required to take corrective action, but in no case less than five minutes.

The limiting condition for voltages should recognize that voltages should not drop below that required for suitable system stability performance, meet the **Nuclear Plant Interface Requirements** and should not adversely affect the operation of the New England **bulk power supply system**.

The limiting condition for equipment loadings should be such that cascading outages will not occur due to operation of protective devices upon the failure of facilities.

2. AREA

An Area (when capitalized) refers to one of the following: New England, New York, Ontario, Quebec or the Maritimes (New Brunswick, Nova Scotia and Prince Edward Island); or, as the situation requires, area (lower case) may mean a part of a system or more than a single system.

3. BULK POWER SUPPLY SYSTEM

The New England interconnected bulk power supply system is comprised of generation and transmission facilities on which faults or disturbances can have a significant effect outside of the local **area**.

4. CONTINGENCY (as defined in NPCC Document A-7)

An event, usually involving the loss of one or more **elements**, which affects the power system at least momentarily.

5. DELAYED FAULT CLEARING (as defined in NPCC Document A-7)

Fault clearing consistent with correct operation of a breaker failure **protection group** and its associated breakers, or of a backup **protection group** with an intentional time delay.

-
6. **ELEMENT** (as defined in NPCC Document A-7)
Any electric device with terminals which may be connected to other electric devices, usually limited to a generator, transformer, circuit, circuit breaker, or bus section.
 7. **EMERGENCY**
An emergency is considered to exist if firm load may have to be reduced because sufficient capacity or energy is unavailable after due allowance for purchases. Emergency transfers are applicable under such conditions. The emergency is considered to exist as long as any firm system load is potentially or actually curtailed.
 8. **EQUIVALENT FORCED OUTAGE RATE**
The equivalent forced outage rate (EFOR) is the ratio of total time a generator is completely forced out of service plus the equivalent full outage time of any forced partial restrictions, to the total time that the unit is not on scheduled maintenance.
 9. **HVDC SYSTEM, DIRECT CURRENT BIPOLAR**
An HVDC system with two poles of opposite polarity.
 10. **NORMAL FAULT CLEARING** (as defined in NPCC Document A-7)
Fault clearing consistent with correct operation of the **protection system** and with the correct operation of all circuit breakers or other automatic switching devices intended to operate in conjunction with that **protection system**
 11. **NUCLEAR PLANT INTERFACE REQUIREMENTS** (as defined in the NERC Glossary of Terms Used in Reliability Standards and as documented in ISO Form NX12)
 12. **PROTECTION GROUP** (as defined in NPCC Document A-7)
A fully integrated assembly of **protective relays** and associated equipment that is designed to perform the specified protective functions for a power system **element**, independent of other groups.

Notes:
 - a) Various identified as Main Protection, Primary Protection, Breaker Failure Protection, Back-Up Protection, Alternate Protection, Secondary Protection, A Protection, B Protection, Group A, Group B, System 1 or System 2.
 - b) Pilot protection is considered to be one protection group.
 13. **PROTECTION SYSTEM** (as defined in NPCC Document A-7)
Element Basis: One or more protection groups; including all equipment such as instrument transformers, station wiring, circuit breakers and associated trip/close modules, and communication facilities; installed at all terminals of a power system **element** to provide the

complete protection of that **element**.

Terminal Basis: One or more protection groups, as above, installed at one terminal of a power system **element**, typically a transmission line.

14. **RESOURCE**

Resource refers to a supply side or demand-side facility and/or action. For the purposes of this procedure, resource means a generating unit, a Demand Resource, a Dispatchable Load, an External Resource or an External Transaction. Demand Resource, Dispatchable Load, External Resource and External Transaction are as defined in Market Rule 1.

15. **SPECIAL PROTECTION SYSTEM (SPS)** (as defined in NPCC Document A-7)

A **protection system** designed to detect abnormal system conditions, and take corrective action other than the isolation of faulted **elements**. Such action may include changes in load, generation, or system configuration to maintain system stability, acceptable voltages or power flows. Automatic under frequency load shedding, as defined in NPCC Emergency Operation Criteria A-3, is not considered an SPS. Conventionally switched, locally controlled shunt devices are not SPSs.

16. **TEN-MINUTE RESERVE** (as defined in NPCC Document A-7)

The sum of synchronized and non-synchronized reserve that is fully available in ten minutes.

17. **WITH DUE REGARD TO RECLOSING** (as defined in NPCC Document A-7)

This phrase means that before any manual system adjustments, recognition will be given to the type of reclosing (i.e., manual or automatic) and the kind of protection.

APPENDIX "B"**GENERAL GUIDELINES FOR DEMONSTRATING COMPLIANCE WITH PLANNING
PROCEDURE NO. 3,
RELIABILITY STANDARDS FOR THE NEW ENGLAND AREA BULK POWER SUPPLY
SYSTEM**

General guidelines for demonstrating compliance with criteria are outlined as follows:

- Testing should be performed to examine the performance of the system. This could be done using "standard" deterministic approaches, and must consider a sufficient range of reasonably stressed system conditions. A consensus of appropriate review groups would be required regarding the adequacy of the system test conditions.
- To demonstrate compliance with criteria:
 - Identify there are no operational restrictions, with all lines in service
and
all load can be served by available **resources** (allowing full use of **ten-minute reserve**, phase shifters, HVDC control, etc.) with any facility assumed already forced out of service.

or
 - If there are operational restrictions or conditions for which all load can not be served:
 - 1) Determine the predicted frequency, duration, period, and magnitude of the restrictions.
 - 2) Convert these findings into a statement describing their effects upon the Governance Participants.
 - 3) Establish the impact of these effects on the reliable and efficient operation of the **bulk power supply system**.

Appropriate review groups will determine the acceptability of restrictions, based on the facts established.

This approach is based on the premise that compliance can be demonstrated if there are no conceivable problems or if it can be proven that potential problems are not significant. As stated, there must be agreement that a sufficient range of system conditions has been analyzed. The significance of any identified problems must be clearly and adequately described; the degree of analysis required will depend on the problem. It may be possible to evaluate the significance of some apparently minor problems by simple means. Problems which appear to be of greater concern may require more

substantial and rigorous analysis.

APPENDIX "C"

DAMPING CRITERION

The purpose of the damping criterion is to assure small signal stability of the New England **bulk power supply system**. System damping is characterized by the damping ratio, zeta (ζ). The damping ratio provides an indication of the length of time an oscillation will take to dampen. The damping criterion specifies a minimum damping ratio of 0.03, which corresponds to a 1% settling time of one minute or less for all oscillations with a frequency of 0.4 Hz or higher. Conformance with the criterion may be demonstrated with the use of small signal eigenvalue analysis to explicitly identify the damping ratio of all questionable oscillations.

Time domain analysis may also be utilized to determine acceptable system damping. Acceptable damping with time domain analysis requires running a transient stability simulation for sufficient time (up to 30 seconds) such that only a single mode of oscillation remains. A 53% reduction in the magnitude of the oscillation must then be observed over four periods of the oscillation, measuring from the point where only a single mode of oscillation remains in the simulation.

As an alternate method, the time domain response of system state quantities such as generator rotor angle, voltage, and interface transfers can be transformed into the frequency domain where the damping ratio can be calculated.

A sufficient number of system state quantities including rotor angle, voltage, and interface transfers should be analyzed to ensure that adequate system damping is observed.